



Christian County Commission

100 West Church St, Room 100
Ozark, MO 65721

SCHEDULED

MEETING ATTACHMENTS (ID # 5433)

Meeting: 01/23/24 09:00 AM
Department: County Clerk
Category: Meeting Items
Prepared By: Madi Hires Raines
Initiator: Madi Hires Raines
Sponsors:

DOC ID: 5433

Meeting Attachments

ATTACHMENTS:

- 23 JAN 2024 PROCLAMATION - NATIONAL MARRIAGE WEEK - 07 FEB - 14 FEB 2024 (PDF)
- 23 JAN 2024 HISTORIC BREAKROOM REMODEL PRESENTATION (PDF)
- 23 JAN 2024 CHANGE ORDER - GOVERNMENT PLAZA WATER & SEWER IMPROVEMENTS - K&B EQUIPMENT (PDF)
- 23 JAN 2024 - MAINTENANCE - 4TH QUARTER REPORT (DOCX)
- 23 JAN 2024 - MAINTENANCE - 4TH QUARTER REPORT - WORK ORDER SUMMARY (PDF)

CHRISTIAN COUNTY MISSOURI COMMISSION PROCLAMATION

National Marriage Week – February 7 through 14, 2024

WHEREAS

Marriage is the foundational relationship for all of society, and good marriages are the bedrock of strong societies, for they are also the foundations of strong families; and

WHEREAS

Marriage continues to be the most popular voluntary institution in that over 90% of individuals in our society marry at least once; and

WHEREAS

Based on a wealth of academic research, married people tend to have healthier lifestyles, live longer, have more satisfying sexual relationships, have more wealth & economic assets, and have children that tend to do better academically and emotionally; and

WHEREAS

Divorce costs, financial & relational, have a significant negative impact on our society, but by supporting and encouraging strong marriages every unit of investment brings a positive multi-fold return into our society; and

WHEREAS

In the state of Missouri and beyond, marriage should be honored by all for the good of all


NOW, THEREFORE, Lynn Morris, Presiding Commissioner of Christian County, Hosea Bilyeu, Western Commissioner of Christian County, Bradley Jackson, Eastern Commissioner of Christian County, all of the great state of Missouri do hereby proclaim on this February 7, 2024 that:

February 7 Through February 14 to Be Recognized as MARRIAGE WEEK

In Christian County Missouri, and recommend that the citizens of Christian County Missouri to recognize the significance and contribution that strong marriages and families have on our society.

COUNTY SEAL

GOES HERE



Christian County Presiding Commissioner
Lynn Morris



Christian County Western Commissioner
Hosea Bilyeu



Christian County Eastern Commissioner
Bradley Jackson

DECORATING DEN

INTERIORS[®]

Christian County Breakroom

Prepared and Presented by:

Jillian Johnson, Design Advisor & Product Specialist





6 chairs
3 tables
5 booths





COPBOARDSSM



COPBOARDS









[View HQ](#)






27D x 6W x 27H
630



25"D x 25"W x 72.8"H
825








24 x 36
Frames: x9


Chadwick




Clever




Ozark



Billings Fair 1910.



Clever



4800



Illuminated



Non-Illuminated



[View HQ](#)



[View HQ](#)



6 chairs
3 tables
5 booths



Christian County Commission

100 W. Church Street Room 100
Ozark, Missouri 65721
(417)582-4300

Lynn Morris
Presiding Commissioner

Bradley A. Jackson
Eastern Commissioner

Hosea Bilyeu
Western Commissioner

January 23, 2024

K&B Equipment
815 McCord Branch Road
Crane, MO 65633

Re: Government Plaza Water & Sewer Improvements Change Order

The Christian County Commission voted in session today to provide a change order to K&B Equipment for the Government Plaza Water & Sewer Improvements for \$25,000. This change order is for additional concrete work for the project. Your point of contact will be Todd Wiesehan. Mr. Wiesehan can be reached at 417-582-4386.



Hosea Bilyeu
Western Commissioner

Date: 1/23/24



Lynn Morris
Presiding Commissioner

Date: 1/23/24



Bradley A. Jackson
Eastern Commissioner

Date: 1-23-2024

BY CHRISTIAN COUNTY AND ONE COPY OF THIS AGREEMENT WILL BE RETURNED TO YOU.

IN WITNESS WHEREOF, the parties have executed and entered into this Agreement as of the date first set forth above.

COUNTY OF CHRISTIAN

CONTRACTOR

By: 
Lynn Morris, Presiding Commissioner

Company Name: _____

By: 
Bradley A. Jackson, Eastern Commissioner

By: _____

By: 
Hosea Bilyeu, Western Commissioner

Title: _____

By: _____

Title: _____

AUDITOR CERTIFICATION

ATTEST BY: 
Paula Brumfield, Christian County Clerk

I certify that the expenditure contemplated by this document is within the purpose of the appropriation to which it is to be charged and that there is an unencumbered balance of anticipated revenue appropriated for payment of same.

Approved as to form:
By: 
N. Austin Fax, Christian County Counselor


Amy Dent, Christian County Auditor

1/29/2024
Date

Date of Issuance: 12/28/2023	Effective Date: 12/28/2023
Owner: Christian County	Owner's Contract No.:
Contractor: K&B Equipment, LLC	Contractor's Project No.:
Engineer: Great River Engineering	Engineer's Project No.: 3817.11
Project: Christian County Government Plaza – Water & Sewer Improvements	Contract Name: Christian County Government Plaza – Water & Sewer Improvements

The Contract is modified as follows upon execution of this Change Order:

Description: Additional concrete work related to the construction of the water and sewer improvements.

Attachments: *[List documents supporting change]*

CHANGE IN CONTRACT PRICE	CHANGE IN CONTRACT TIMES <i>[note changes in Milestones if applicable]</i>
Original Contract Price: \$ 1,137,548.00	Original Contract Times: Substantial Completion: 180 Ready for Final Payment: 210 days or dates
[Increase] [Decrease] from previously approved Change Orders No. ___ to No. ___: \$ n/a	[Increase] [Decrease] from previously approved Change Orders No. ___ to No. ___: Substantial Completion: n/a Ready for Final Payment: _____ days
Contract Price prior to this Change Order: \$ 1,137,548.00	Contract Times prior to this Change Order: Substantial Completion: 180 Ready for Final Payment: 210 days or dates
[Increase] [Decrease] of this Change Order: \$ 25,000.00	[Increase] [Decrease] of this Change Order: Substantial Completion: 30 Ready for Final Payment: 30 days or dates
Contract Price incorporating this Change Order: \$ 1,162,548.00	Contract Times with all approved Change Orders: Substantial Completion: 210 Ready for Final Payment: 240 days or dates

RECOMMENDED:		ACCEPTED:		ACCEPTED:	
By: 	By: _____	By: _____	By: _____	By: _____	By: _____
Engineer (if required)	Owner (Authorized Signature)	Owner (Authorized Signature)	Contractor (Authorized Signature)	Contractor (Authorized Signature)	Contractor (Authorized Signature)
Title: Lead Project Engineer	Title: _____	Title: _____	Title: _____	Title: _____	Title: _____
Date: 12/28/2023	Date: _____	Date: _____	Date: _____	Date: _____	Date: _____

2023 4thQuarterly Report

General maintenance

1. All H-vac building filters were replaced.
2. Repaired a lot of H-vac issues such as low coolant, replaced contractors and called in service tech for serval more issues.
3. Jail plumbing issues are on going. Clogged drain due to inmates and kitchen staff.
4. We continue to monitor the water softener system weekly and made adjustments as needed.
5. I welded an inmates stool in booking after inmate broke the top off.
6. Repaired seating in the public lobby at the Justice Center
7. Added metal step edges to Judge Bacons court room as requested.
8. Cleared debris from jail locks as requested.
9. Rebuilt Drivers Door on 2008 Chevy truck.
10. Built a lactating room in the mules office. (this is a temporary room and will be removed at a later date.)

Special projects.

1. We built a 23-foot snowman.
2. Worked with HRD on the Friday night events.
3. Installed the Christmas lights.
4. Purchased 5 booths and 3 tables with chairs for Breakroom project.
5. Worked with IT Department to get server room ready at the Circuit Court building and added power supported by the generator.
6. Replaced the carpet in Judge Bacons courtroom.
7. Painted the storage room in Amy Dents office.

New Equipment

1. Building Maintenance purchased 1 new lawn mower.
2. The Sheriff transferred a Chevy 2500 4x4 pickup truck with snowplow to the Building Maintenance Dept.

New projects for 2024

1. Update the Breakroom at the Historic Building.
2. Update the men's 2nd floor Restroom at the historic building.
3. Work to find and repair leak at the county Jail. (roof or wall)
4. Get quotes to clean and seal brick at Justice Center.

5. The sheriff is remodeling the booking area in the jail. We will asset as needed and hope to replace the shower lighting at the same time- around March 2024.
6. Finish carpet replacement outside of Judge Bacons courtroom.
7. Add gazebo ramp for Wheelchair accessibility.

Jail Sewer project

I'm still working with Great River to move forward with this project.

Elevator maintenance

We now have Kone Elevators as our maintenance contractor.

We are finally making progress with the phone issues and other maintenance items. We will be fully state compliant. A new Wi-fi phone system will be installed with a 24-hour monitoring contract.

I will also take over the monthly elevator fire inspections as suggested by the state inspector.

Current issues waiting on parts.

C-pod exhaust fan motor

On demand water internal parts from Draper Plumbing

We are fully staffed with a great crew and continue to answer requests as they come in.

Richard Teague 1/20/24

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 1 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000392	Completed	Non-PM	High	Reactive Maintenance	Elevators	Facilities		Justice Center	Richard Teague	01/16/2024	01/16/2024	01/16/2024	18.11	1.00
call elevator repair/ kone														

Elevator company came out and lubed the slides and the elevator is not jumping or making anymore noise

WO000391	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	01/16/2024	01/16/2024	01/16/2024	13.58	0.75
B Pod having issues with shower drain														
Used drain o and plunger and got it draining like it should														

WO000390	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	01/15/2024	01/16/2024	01/16/2024	30.06	1.66
Toilet was flushed and then failed to drain also overflowing the bathroom floor Multiple times with the plunger were attempted, no resolution														
Took a new plunger and scrub brush over to this restroom and plunged the toilet and it flushed as it should several times.														

WO000389	Completed	Non-PM	High	Preventive Maintenance	Winterization Preparation	Facilities		County Jail	Kit Grimes	01/12/2024	01/12/2024	01/16/2024	64.98	3.00
Pre salt all sidewalks and parking lots.														
Salted all sidewalks and all parking lots.														

WO000388	In Progress	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Richard Teague	01/12/2024	01/12/2024		0.00	0.00
repair jail water heater leak														
called in at 1:30am shut water off to heater. will call in plumbing company after 8:00am bypass valve open to backfeed cell block E and F														

WO000387	Completed	Non-PM	Medium	Reactive Maintenance	Special Projects	Facilities		Justice Center	Lindale Cummings	01/11/2024	01/11/2024	01/16/2024	55.78	3.08
----------	-----------	--------	--------	----------------------	------------------	------------	--	----------------	------------------	------------	------------	------------	-------	------

Work Order Summary w/ Details

Date Printed: 01/17/2024

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

We need two televisions hung in the CCSO training room.

Installed both tvs as the sheriff directed.

WO000386	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	01/10/2024	01/10/2024	01/10/2024	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Toilet is stopped up

Removed clogged from toilet.

WO000385	In Progress	Non-PM	Medium	Reactive Maintenance	Special Projects	Facilities		Historic Building	Kit Grimes	01/09/2024	01/11/2024		0.00	0.00
----------	-------------	--------	--------	----------------------	------------------	------------	--	-------------------	------------	------------	------------	--	------	------

remove all paint from windows.

WO000384	New Work Order	Non-PM	Medium	Reactive Maintenance	Equipment Maintenance	Facilities		Circuit Court Building	Kit Grimes	01/09/2024	01/22/2024		0.00	0.00
----------	----------------	--------	--------	----------------------	-----------------------	------------	--	------------------------	------------	------------	------------	--	------	------

Replace Batteries in Judge parking gate

WO000383	New Work Order	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		Resource Building	Kit Grimes	01/09/2024	01/18/2024		0.00	0.00
----------	----------------	--------	--------	----------------------	----------	------------	--	-------------------	------------	------------	------------	--	------	------

replace all batteries in all flush valves and sinks

WO000382	Completed	Non-PM	Medium	Reactive Maintenance	HVAC	Facilities		County Jail	Kit Grimes	01/09/2024	01/19/2024	01/11/2024	0.00	0.00
----------	-----------	--------	--------	----------------------	------	------------	--	-------------	------------	------------	------------	------------	------	------

Replace all batteries in thermostats in all buildings as needed.

Went to Lowe's and got batteries and went to all buildings and changed out all batteries in thermostats

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 3 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

W00000381	Completed	Non-PM	Medium	Reactive Maintenance Lighting	Facilities	HR Building	Lindale Cummings	01/09/2024	01/09/2024	01/09/2024	409.80	20.00
replace light in HR building lobby												
Replaced light bulbs												

[illegible]

WO0000379	Completed	Non-PM	High	Reactive Maintenance	Mechanical Facilities	County Jail	Kit Grimes	01/08/2024	01/09/2024	01/09/2024	0.00	0.00
Door in B Pod will shut but will not open up after being closed												
Changed fuse in fuse panel in booking												

WO#	Status	Priority	Category	Location	Assigned To	Due Date	Hours	Cost
WO000378	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Kit Grimes
Sinks are not draining in either cell. Staff attempted to use plunger with negative results.							01/08/2024	01/08/2024
Sinks drain as they should.							01/09/2024	13.58
							0.75	

WO#	Completed	Non-PM	High	Reactive Maintenance Projects	Facilities	Maintenance Shop	Richard Teague	01/08/2024	01/10/2024	01/11/2024	72.00	3.00
WO000377	Completed	Non-PM	High									
Move all custodial cleaning products from the shop to the circuit court building.												
moved all cleaning products from shop building to circuit court building storage.												

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 4 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expedited	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000375	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Historic Building	Lindale Cummings	01/05/2024	01/08/2024	01/08/2024	10:25	0.50
Personal Property has a Light going out													
Replaced all 4 bulbs. Working fine													

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	01/03/2024	01/04/2024	01/08/2024	30.74	1.50
Shower drain is extremely slow, backing up into the booking area. Have attempted plunging it, but no improvement.													
Tried draino with no success then tried clobber no success then plunged on it for 15 more minutes and it went down.													

[illegible]

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Electrical	Facilities	Justice Center	Lindale Cummings	12/29/2023	01/02/2024	01/02/2024	48.00	2.00
lights in the evidence hall not turn on, may be out. POC is Kathy, Evidence Custodian													
replaced all light bulbs.													

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Kit Grimes	12/29/2023	12/29/2023	01/02/2024	0.00	0.00
WO000371	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Kit Grimes	12/29/2023	12/29/2023	01/02/2024	0.00	0.00
There is a light out in room 109 lobby													
replaced bad lights													

Account Number	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	12/27/2023	12/28/2023	12/28/2023	21.19	1.17
VO0000370	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	12/27/2023	12/28/2023	12/28/2023	21.19	1.17

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 5 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expeded	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

Toilet was clear and working as it should adjusted sink timer for both flow valves and replaced on button everything was working as it should. *cannot adjust water pressure**

	Completed	Non-PM	Medium	Preventive Maintenance Plumbing	Facilities	County Jail	Lindale Cummings	12/27/2023	12/28/2023	12/28/2023	18.1	1.00
WO000369	Completed	Non-PM	Medium	Preventive Maintenance Plumbing	Facilities	County Jail	Lindale Cummings	12/27/2023	12/28/2023	12/28/2023	18.1	1.00
sink is clogged.												
Cleared both 248 and 249 sinks in f pod												

Cleared both 248 and 249 sinks in f pod

WO#	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	12/26/2023	12/26/2023	12/26/2023	13.58	0.75
WO000368	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	12/26/2023	12/26/2023	12/26/2023	13.58	0.75

Replace toilet button

Toilet button in D pod had been messed with and unbolted from the wall. Bolted it back to the wall.

	Reactive Maintenance ^e	Plumbing	Facilities	County Jail	Richard Teague		
WO000367	Completed	Non-PM	Medium				
				12/22/2023	12/26/2023	12/26/2023	0.00 0.00

Don't move certain materials in cell severely foul's central floor drain. Make sure it is draining as it should before you leave. Sheriff is taking steps to make sure no more delegating or trash is in this drain we can move forward

Dumped a whole bottle of draino down it and rinsed out. Draining fine

WO000366	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings					
	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	12/22/2023	12/22/2023	12/26/2023	24.00	1.00

On 7/4/08, Sheriff Cole's understanding, there have been multiple requests for this in the past but never fully resolved.

arr Better snaked it out

is my understanding you are allowing inmates to defecate in the floor drain, this is meant for urine only. This problem will continue to happen until this is addressed. No debris, no toilet paper, not anything other than urine, is to be in these drains. They are meant for Liquid only.

Preventive Maintenance	Lighting	Facilities	County Jail	Lindale Cummings	12/20/2023	12/21/2023	12/21/2023	10.50	0.58
Completed	Non-PM	Medium							

pod right shower light is not working

replaced the bulbs

Work Order Summary w/ Details

Date Printed: 01/17/2024

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000364	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	12/20/2023	12/21/2023	12/21/2023	0.00	0.00
The Drain in cell 74 in booking is still not working at all														
Poured clobber down it. There still letting inmates poop in it probably have to call rotoooter Going down slowly														

WO000363	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	12/20/2023	12/21/2023	12/21/2023	18.11	1.00
Light in E 155 is out and the left shower light is not working														
New bulbs in shower and cell 155.														

WO000362	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		County Jail	Lindale Cummings	12/20/2023	12/21/2023	12/21/2023	18.11	1.00
Light in A 225 is not working														
Replaced bulbs and ballist														

WO000361	Completed	Non-PM	Low	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	12/19/2023	12/21/2023	12/21/2023	10.25	0.50
request sent in for C-pods lower tier sink, the lower tier sink has high water pressure causing water to get on the floors and the left showers nozzle needs adjusted														
Done what we could. There's no adjustment on water pressure. And vent was running fine														

WO000360	On Hold	Non-PM	Low	Reactive Maintenance	HVAC	Facilities		County Jail	Richard Teague	12/19/2023	12/27/2023		0.00	0.00
C Pod Exhaust Fan not working														
waiting for quote														

WO000359	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	12/19/2023	12/21/2023	12/21/2023	9.06	0.50
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 7 of 69

[illegible]

Sinks in F pod, Cells 165-166 are clogged

Sink was clogged with hair and soap cleared both

	Completed	Non-PM	Medium	Reactive Maintenance	General Maintenance	Facilities	Justice Center	Lindale Cummings	12/18/2023	12/19/2023	12/21/2023	5.98	0.33
WO000358				e	e								
The soap dispenser in the women's squad room bathroom broke.													
The soap dispenser works but the handle feels loose it is not broken.													

The soap dispenser works but the handle feels loose it is not broken.

[illegible]

Jail kitchen garbage disposal and floor drains clogged

Attempted to snake out drains was unsuccessful contacted roto router they will Be on site between five and seven pm tonight.

[illegible]

the staircase behind the clerk, up to the door and judge bench - there is a plastic thing off of the floor exposing the wood.

ut glue down and reattached it to the floor.

[illegible]

There is a flickering light kind of in the walkway area right by the copy machine in my office area on the 2nd floor.

replaced bulbs

[illegible]

install shelf for sound equipment and commission meeting room.

chored shelf to wall for 1 T

Page 8 of 69

.....

.....

Work Order Summary w/ Details

Date Printed: 01/17/2024

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000348	Completed	Non-PM	High	Reactive Maintenance	Mechanical	Facilities		County Jail	Lindale Cummings	12/07/2023	12/07/2023	12/08/2023	0.00	0.00
----------	-----------	--------	------	----------------------	------------	------------	--	-------------	------------------	------------	------------	------------	------	------

The Overhead Door for Shipping and Receiving is not opening. We have deliveries coming in today. ASAP please

Check breakers, turn breakers back on, breakers flipped again. Electrical smell coming from electric motor on door opener. Contacted overhead door for service and repair.

WO000347	Completed	Non-PM	High	Vandalism	Plumbing	Facilities		County Jail	Richard Teeque	12/06/2023	12/06/2023	12/07/2023	24.00	1.00
----------	-----------	--------	------	-----------	----------	------------	--	-------------	----------------	------------	------------	------------	-------	------

I need someone to show me how to turn the water off to individual cells. Due to recent flooding of cells by inmates, this is something that is needed please.

supplied tool and showed how to shut water off.

WO000346	Completed	Non-PM	High	Reactive Maintenance	Lighting	Facilities		Justice Center	Lindale Cummings	12/06/2023	12/06/2023	12/07/2023	38.60	2.00
----------	-----------	--------	------	----------------------	----------	------------	--	----------------	------------------	------------	------------	------------	-------	------

The lights up front are still out. The ladies said the bulbs were replaced but the lights are still out. Maybe there is another issue going on? it is pretty dark up there with both lights out.

replaced lights.

WO000345	Completed	Non-PM	Medium	Reactive Maintenance	Painting	Facilities		Historic Building	Lindale Cummings	12/06/2023	12/06/2023	12/14/2023	72.44	4.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------------	------------------	------------	------------	------------	-------	------

Paint the auditor storage room second floor history courthouse.

WO000344	Completed	Non-PM	Medium	Reactive Maintenance	Special Events	Facilities		Justice Center	Richard Teeque	12/05/2023	12/05/2023	12/18/2023	240.52	11.98
----------	-----------	--------	--------	----------------------	----------------	------------	--	----------------	----------------	------------	------------	------------	--------	-------

Check all snowblowers, make sure battery maintainers are on all snow blowers. Make sure all buildings have a snow shovel. Confirm all trucks and the tractor and polaris ranger have a ice Scrape fuel treat equipment, add ice scraper as needed, replace Whipper on skid steer put out snow shovel put battery maintainer on all snow equipment.

WO000343	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		Historic Building	Lindale Cummings	12/04/2023	12/05/2023	12/04/2023	20.49	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------------	------------------	------------	------------	------------	-------	------

2nd floor Womens Restroom by Supply Closet & Mens RR is clogged.

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 10 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

Plunged toilet works fine

WO#	Completed	Non-PM	Low	Reactive Maintenance Projects	Special Facilities	Circuit Court Building	Lindale Cummings	12/01/2023	12/01/2023	12/01/2023	18.11	1.00
WO0000342	Completed	Non-PM	Low									

Can we have Maintenance come over and put some Anchors in the wall so Adam can hang 3 pictures- They are a little heavy and we want to make sure they stay on the wall and dont fall- He is here today if they are available shouldnt take but a few minutes- Dale can also assist in locations if Adam is in court- thanks

put anchors in the wall for the pictures to hang on

WO000341	Completed	Non-PM	Medium	Reactive Maintenance e	Lighting	Facilities	Justice Center	Lindale Cummings	11/29/2023	11/29/2023	12/01/2023	10:50	0.58

We have a flickering light right above the attorney printer to the left of the court staff door
replaced 2 bulbs

	Completed	Non-PM	Medium	Reactive Maintenance e	Water Leaks	Facilities	County Jail	Lindale Cummings	11/29/2023	11/30/2023	12/01/2023	0.00	0.00
V00000340	Completed	Non-PM	Medium	Reactive Maintenance e	Water Leaks	Facilities	County Jail	Lindale Cummings	11/29/2023	11/30/2023	12/01/2023	0.00	0.00

this is the ROS I received from an inmate... during lockdown today out can hear the cold water continue to run in the sink behind the wall when you press the cold button it runs into sink till it's full flooding the room if you press the hot it will stop running in sink but you hear it in the wall, although we put a sign on wall that says press hot after cold its breaking a rule attaching things to our cell wall for those who can't read to press the hot after cold or not at all they still do, we have to keep a towel or washcloth to catch the water creating wet towels for mold to grow there is mold growing under the toilet and sink and water still runs even not pressing the button you can hear it in the wall.

replaced 2 flow through valves

0000338	Completed	Non-PM	Medium	Reactive Maintenance	Special Projects	Facilities	Justice Center	Richard Teague	11/29/2023	11/29/2023	11/29/2023	24.00	1.00
---------	-----------	--------	--------	----------------------	------------------	------------	----------------	----------------	------------	------------	------------	-------	------

Richard, thank you for moving the fridge from the Ranch to the Evidence room. I believe this was a request from Sheriff Cole

oved refrigerator from the ranch house to evidence room.

[illegible]

edge in Evidence repair/maintenance

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 12 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000332 Completed Non-PM High Reactive Maintenance Mechanical Facilities Justice Center Lindale Cummings 11/17/2023 11/17/2023 11/17/2023 0.00 0.00

The security door magnet from "green mile" to the Evidence hall is coming off and also showing wires. Sheriff Cole states this is a major issue and security risk. replaced missing screw.

WO000331 Completed Non-PM Low Reactive Maintenance Custodial Facilities Justice Center Richard Teague 11/17/2023 11/22/2023 11/20/2023 0.00 0.00

Cpt. Seiner is requesting the middle room's carpet be shampooed and cleaned, please. Custodian is cleaning monday morning. Please remove any unnecessary items from this area. The carpet has been cleaned.

WO000330 Completed Non-PM High Reactive Maintenance Plumbing Facilities Justice Center Lindale Cummings 11/16/2023 11/16/2023 11/20/2023 0.00 0.00

The Janitor's Closet located in the squad room is flooded with standing water and present mold. removed sheetrock, contacted plumber who installed drain for repairs. plumber will be on-site today for Solution. Hanbey construction on-site for warranty if necessary. 10:15

WO000329 Completed Non-PM Medium Reactive Maintenance Lighting Facilities Justice Center Lindale Cummings 11/16/2023 11/16/2023 12/01/2023 18.11 1.00

Lights are out on both side of front counter. Replaced bulbs.

WO000328 Completed Non-PM High Reactive Maintenance Plumbing Facilities County Jail Lindale Cummings 11/14/2023 11/14/2023 11/15/2023 18.11 1.00

Toilet in A Pod cell 128 is not flushing. Went in Tuesday and court was being held and jail was short staffed so I was asked to return another time. Went in wednesday and the toilet was working as it should be.

WO000327 Completed Non-PM High Reactive Maintenance Lighting Facilities Justice Center Lindale Cummings 11/09/2023 11/09/2023 11/13/2023 0.00 0.00

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 13 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expedited	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

There is a light out above the TV and another one that flickers to the immediate left of the door, as looking from the bench. Thanks

Replaced bulbs all working as they should be.

WO#	Category	Subcategory	Priority	Assigned To	Assigned Date	Estimated Hours	Actual Hours
WO000326	On Hold	Non-PM	Medium	Reactive Maintenance	Carpentry	Facilities	
				Historic Building	Lindale Cummings	11/08/2023	11/08/2023
						0.00	0.00
TWO MONEY DRAWERS INSTALLED AT COUNTER IN COLLECTOR OFFICE							

W00000325	Completed	Non-PM	Medium	Reactive Maintenance e	General Maintenance e	Facilities	HR Building	Lindale Cummings	11/03/2023	11/03/2023	11/03/2023	0.00	0.00
fix or replace soap dispenser in hr building													

Megan put too much soap in it. We poured some out and checked. No leak found. And moped floor.

WO#	Completed	Non-PM	High	Reactive Maintenance	Equipment Maintenance	Facilities	Mower-002	Maintenance Shop	Lindale Cummings	11/02/2023	11/02/2023	11/03/2023	0.00	0.00
Replace belt on matt mower														
Went to Jofitis and got new belt and installed on mower.														

[illegible]

They were alarmed and felt it needed to be checked out. Wendy and Kim witnessed a loud pop, and something to the nature behind the outlet was pushed out/disassembled.

Plastic cover broke outlet is fine

[illegible]

For example, water has worms or some type of parasite that comes out of the water supply. These black worm like critters are definitely moving, living parasites. Water is unsafe for consumption or usage.

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 14 of 69

[illegible]

Ran water found no evidence of worms coming out of fresh water sink. I did find worms coming up out of sink drain. He uses clobber drain cleaners to clear out the sink drain and remove pests. sink is working as it should, no more worms found after actions taken.

WO#	Declined	Non-PM	Low	Preventive Maintenance	General Maintenance	Circuit Court	Building	11/01/2023	11/02/2023	0.00	0.00
WO0000321	Declined	Non-PM	Low	Preventive Maintenance	General Maintenance	Circuit Court	Building	11/01/2023	11/02/2023	0.00	0.00

Friday is Mary Ann's last day, her and a couple of the others are wanting to clean out my old law books that are no longer in use. Is there anyway they can have help and also have them loaded up to take to the recycling center? please let me know if that is an option. thanks

Not able to do this this week. I have prior commitments through saturday the eighteenth. Maybe able to help after that day.

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Carpentry	Facilities	Justice Center	Lindale Cummings	11/01/2023	11/02/2023	11/03/2023	21.19	1.17
WO0000320	Completed	Non-PM	Medium	Reactive Maintenance	Carpentry	Facilities	Justice Center	Lindale Cummings	11/01/2023	11/02/2023	11/03/2023	21.19	1.17

WO#	Status	Priority	Reactive Maintenance	Special Projects	Facilities	Circuit Court Building	Assigned To	Due Date	Estimate	Comments
WO0000319	On Hold	Non-PM	Low				Lindale Cummings	11/01/2023	11/06/2023	0.00
Richard - Anna was wondering if Kit and Lindel could possibly hang up here pictures on her wall now that we have painted her office. They will be heavy ones like Nick's office - (5 framed) that we want to make sure they are secure in the walls. She said Thursday or Friday this week works for her if it will fit into their schedules- she has the framed photos here if they need to see them first. They will probably need the wall anchors. Went to hang pictures and she was not in her office. Will have to wait for another day										

WO#	Status	Priority	Category	Location	Assigned To	Start Date	End Date	Hours
WO000318	Completed	Non-PM	Reactive Maintenance	County Jail	Kit Grimes	10/31/2023	10/31/2023	0.00
repair water leak in 54s at water heater								
Called Draper plumbing Robert came out with new valve and fixed water heater and tested. No leaks found.								

	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Historic Building	Lindale Cummings	10/30/2023	10/30/2023	10/31/2023	0.00	0.00
W/O000317	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Historic Building	Lindale Cummings	10/30/2023	10/30/2023	10/31/2023	0.00	0.00
Replace light bulbs in presiding commissioner's office.													
Ballast was bad and put in 2 new bulbs													

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 15 of 69

[illegible][illegible]

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	10/24/2023	10/24/2023	10/25/2023	27.17	1.50
WO000315	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	10/24/2023	10/24/2023	10/25/2023	27.17	1.50
Light replacement to the office straight ahead from coming in from Trish's door. Photos attached. (There is one out in Detective Law & Collins' office but they request it is NOT replaced) Replaced 6 bulbs in 2 panel lights.													

[illegible]

WO#	Completed	Non-FM	Medium	Reactive Maintenance e	Plumbing	Facilities	County Jail	Lindale Cummings	10/24/2023	10/24/2023	10/24/2023	0.00	0.00
WO000313	Completed	Non-FM	Medium	Reactive Maintenance e	Plumbing	Facilities	County Jail	Lindale Cummings	10/24/2023	10/24/2023	10/24/2023	0.00	0.00

	Completed	Non-PM	Medium	Reactive Maintenance Lighting	Facilities	County Jail	Lindale Cummings	10/24/2023	10/24/2023	10/24/2023	18.11	1.00
O/0000312	Completed	Non-PM	Medium									
lights out in Cell 230, B Pod												
Cells 229 and 230 lights was not working due to a bad night light. Replaced night light bulb and all lights are working properly.												

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 16 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000311	Completed	Non-PM	High	Reactive Maintenance	Lighting	Facilities	Justice Center	Justice Center	Lindale Cummings	10/23/2023	10/23/2023	10/24/2023	18.11	1.00
Judge Bacon's bailiff asked that I send this request. There are some lighting issues in the courtroom. Dan Kingsbury is the person to talk to about which ones need to be looked at or replaced.														
Replaced all lights that were not working.														

WO000310	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities	County Jail	County Jail	Lindale Cummings	10/23/2023	10/23/2023	10/24/2023	0.00	0.00
Shower in F Pod will not shut off, is running constantly.														
Put in new flow through valve. Works fine														

WO000309	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	County Jail	County Jail	Lindale Cummings	10/23/2023	10/23/2023	10/24/2023	0.00	0.00
Lights are out in cell 223 and 229. At night when night lighting comes on, lights in pod strobe/flicker.														
Lights in 229 and 230 they are working.														

WO000308	Completed	Non-PM	Low	Reactive Maintenance	Carpentry	Facilities	Historic Building	Historic Building	Lindale Cummings	10/23/2023	10/23/2023	10/24/2023	18.11	1.00
Add ballot magazine holders to the wall in the election office.														
Got all 6 mounted on the wall as directed.														

WO000307	Completed	Non-PM	Low	Reactive Maintenance	HVAC	Facilities	Historic Building	Historic Building	Richard Teague	10/23/2023	10/23/2023	10/26/2023	0.00	0.00
Removal of old Heating unit from a wall in storage room.														
Removed heater and put box on wall to hide wires														

WO000306	Completed	Non-PM	Low	Reactive Maintenance	Special Projects	Facilities	Circuit Court Building	Circuit Court Building	Lindale Cummings	10/23/2023	10/23/2023	10/24/2023	9.06	0.50
----------	-----------	--------	-----	----------------------	------------------	------------	------------------------	------------------------	------------------	------------	------------	------------	------	------

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 17 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

So Nick has his pictures here that need to be hung whenever maintenance is available to assist - Mounted all 3 pictures on the wall as directed.

WO000305 Completed Non-PM High Reactive General Maintenance e
JCI was out to test the door lock relays. They determined the door lock itself not working correctly and the do not service the actual door locks. This the exit door from the prosecutors office on the main level that exits to the secure parking area.
J ay key service come out and repair lock.

WO000304 Declined Non-PM Low Reactive General Maintenance e
The dishwasher is not working. I have done all I know to do to get it to work.

We do not work on kitchen equipment. You should call Complete kitchen service 417-581-0223

WO000303 Completed Non-PM Medium Reactive General Maintenance e
Need access to Public PC box in Jail Public Sally Port - Don't have bit needed,Also, will need a notch cut for Mouse and Keyboard.
Went to Lowe's and got Bill a bit set

WO000302 Completed Non-PM Low Reactive Special Maintenance Projects e
Could we have maintenance come and help Nick to hang some pictures, and a heavy framed license- ? This Friday or the next Monday are good times for Nick if someone is available - Nick's office is right by mine (Date)
Put 3 hangers in wall

WO000301 Completed Non-PM High Reactive Maintenance Plumbing Facilities e
Kitchen Bathroom has over flowed again to and still stopped up

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 18 of 69

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

Chelsey already cleared it.

WO000299	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	10/16/2023	10/17/2023	10/20/2023	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

The drain on the left shower in B-Pod is not draining properly

Draining fine. There always complaining it's not. But it is

WO000300	Completed	Non-PM	High	Reactive Maintenance	Lighting	Facilities		County Jail	Lindale Cummings	10/16/2023	10/17/2023	10/20/2023	0.00	0.00
----------	-----------	--------	------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

The light in cell 230 is also out currently.

Put in new ballast

WO000298	Completed	Non-PM	Medium	Reactive Maintenance	Painting	Facilities		Justice Center	Lindale Cummings	10/13/2023	10/13/2023	10/20/2023	18.11	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	----------------	------------------	------------	------------	------------	-------	------

Repair sheet rock and paint office

Put a coat of sheet rock mud on still needs more work. Finished muddying walls and painted entire office

WO000297	Completed	Non-PM	Medium	Reactive Maintenance	Other	Facilities		Justice Center	Kit Grimes	10/13/2023	10/13/2023	10/16/2023	0.00	0.00
----------	-----------	--------	--------	----------------------	-------	------------	--	----------------	------------	------------	------------	------------	------	------

Repair or replace paper towel dispenser.

Drilled holes in unit and put spring on. But a new one has been ordered. Should be replaced soon

WO000296	Declined	Non-PM	Low	Inspections	Inspection	Facilities		Historic Building	Richard Teague	10/12/2023	10/12/2023		0.00	0.00
----------	----------	--------	-----	-------------	------------	------------	--	-------------------	----------------	------------	------------	--	------	------

Linda Myers, who works for me as a special assistance clerk - she retired from the state - she needs to get into the basement to look to see if we have any missing books (big books) in the basement. She has been in there before, but it has been years ago. She is in my office (2nd floor) until 4:30 today. We are thinking she only needs 20 minutes to look and bring back any books that are ours. Can one of your staff let her in? Thanks/she will be here other days as well. You can text me if you need anything - and i can get her. I am on a video meeting right now. thanks!

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 19 of 69

[illegible]

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Historic Building	Lindale Cummings	10/10/2023	10/10/2023	10/11/2023	543.30	30.00
W0000295	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Historic Building	Lindale Cummings	10/10/2023	10/10/2023	10/11/2023	543.30	30.00
Is a story building entrance change light bulbs.													
Replaced the bulb													

	Declined	Non-PM	Low	Reactive Maintenance	Other	Facilities	Justice Center			
WO000294	Declined	Non-PM	Low	e				10/10/2023	10/10/2023	0.00

Can we please get some kind of strips put on the carpet on the ledges in the courtroom? The new carpet makes it very difficult to see where we need to step down. There is a step down on the clerk side and on the inside where the bailiff sits. Judge Bacon may want something on the steps going up to the bench as well.

	Completed	Non-FM	High	Reactive Maintenance e	Other	Facilities	Justice Center	Richard Teague	10/06/2023	10/06/2023	10/11/2023	153.96	7.00
WO0000293	Completed	Non-FM	High	Reactive Maintenance e	Other	Facilities	Justice Center	Richard Teague	10/06/2023	10/06/2023	10/11/2023	153.96	7.00
Replace all benches and furniture in courtroom													
Put benches and bolted down all of them.													

WO#	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	10/05/2023	10/05/2023	10/06/2023	0.00	0.00
WO000292	Completed	Non-PM	High									0.00	0.00
Kitchen Bathroom is stopped up, needs fixed ASAP please													
Repaired drain													

00000291	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	10/02/2023	10/02/2023	10/02/2023	18.11	1.00
The sinks in C-Pod on the top tier are backing up and things coming out of the drain into the sink and overflowing.													
Sinks drain as the should.													

Case Number	Completed	Non-PM	Medium	Vandalism	Lighting	Facilities	County Jail	Lindale Cummings	10/02/2023	10/02/2023	10/02/2023	36.22	2.00
00000290	Completed	Non-PM	Medium	Vandalism	Lighting	Facilities	County Jail	Lindale Cummings	10/02/2023	10/02/2023	10/02/2023	36.22	2.00

Work Order Summary w/ Details

Date Printed: 01/17/2024

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO000284	Completed	Non-PM	Low	Reactive Maintenance ^e	Special Projects	Facilities		Maintenance Shop	Richard Teague	09/28/2023	09/28/2023	10/11/2023	92.21	4.50
Paint outdoor Christmas decoration.														
Started painting snowman														

WO000283	Completed	Non-PM	Medium	Reactive Maintenance ^e	HVAC	Facilities		Historic Building	Richard Teague	09/28/2023	09/12/2023	10/13/2023	0.00	0.00
Air conditioner in vault is not working. Was not fixed from prior request.														
Contact night's heating and air. Should be out today.														

WO000282	Completed	Non-PM	Medium	Reactive Maintenance ^e	Electrical	Facilities		Circuit Court Building	Richard Teague	09/27/2023	09/27/2023	09/29/2023	199.21	11.00
help get the electrician in and out of building 3 as needed.														
Give access to work area.														

WO000281	Completed	Non-PM	Medium	Reactive Maintenance ^e	Special Projects	Facilities		Historic Building	Richard Teague	09/27/2023	09/27/2023	09/27/2023	0.00	0.00
replace flowers														
Went to Walmart and bought 14 big beautiful mums and took to historic courthouse and filled all planters. Looks fantastic.														

WO000280	Completed	Non-PM	Medium	Reactive Maintenance ^e	Mechanical	Facilities		Truck-003 Maintenance Shop	Lindale Cummings	09/26/2023	09/26/2023	09/26/2023	40.75	2.25
Drivers door broken on 2008 Silverado 1500														

Door busted out around lower hinge removed door and welded and braced the cracks.

WO000279	Completed	Non-PM	Medium	Reactive Maintenance ^e	Other	Facilities		County Jail	Lindale Cummings	09/26/2023	09/26/2023	09/26/2023	36.22	2.00
----------	-----------	--------	--------	-----------------------------------	-------	------------	--	-------------	------------------	------------	------------	------------	-------	------

Page 23 of 69

Test S	Hour(s)
--------	---------

23 2.50

0.0	0.75
.....	
.....	

00.0 0

3	1.02
.....	
.....	

0.00

Work Order Summary w/ Details

Date Printed: 01/17/2024

Page 24 of 69

[illegible]

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	09/20/2023	09/21/2023	09/21/2023	0.00	0.00
WO000268	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	09/20/2023	09/21/2023	09/21/2023	0.00	0.00
Need a new light bulb in courtroom. In between door to office area and door to secure hallway ...on the wall with tv													
Put in 2 new bulbs													

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	09/20/2023	09/20/2023	09/25/2023	0.00	0.00
WO000267	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	09/20/2023	09/20/2023	09/25/2023	0.00	0.00
Cells in E-pod#153 - no hot water will not come out#154- only hot water will come out#155 - no hot water comes out This stuff was passed to me during my supervisor walk through I know it's a lot, im just passing up the info I have.													
All have been repaired. New vacuum buttons for all 3 cells													

WO#	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	09/19/2023	09/19/2023	09/21/2023	10.25	0.50
W0000266	Completed	Non-PM	High										
Kitchen Mop closet faucet leaking onto floor.													
Went to Lowe's got new 4 way valve and put it on. Worked fine													

WO0000265	Declined	Non-PM	Low	Vandalism	Plumbing	Facilities	County Jail	09/14/2023	09/18/2023	0.00	0.00
130 is overflowing causing to potentially have to try to rehause people.											

was fixed last week

WO0000264	Declined	Non-PM	Low	Reactive Maintenance	Plumbing	Facilities	County Jail	09/14/2023	09/18/2023	0.00	0.00
The sink in 127 is overflowing and potentially have to try to rehause people											
already fixed last week.											

WO0000263	Completed	Non-PM	High	Vandalism	Plumbing	Facilities	County Jail	Lindale Cummings	09/14/2023	09/15/2023	09/15/2023	0.00	0.00
Cell 127 sink and cell 130 toilets are overflowing.													

Date Printed: 01/17/2024

[illegible]

Sink in 127 and 128 cleared Thursday

WO#	Completed	Non-PM	High	Reactive Maintenance	Electrical	Facilities	County Jail	Lindale Cummings	09/14/2023	09/15/2023	09/15/2023	0.00	0.00
W0000262	Completed	Non-PM	High									0.00	0.00
Kitchen advised dishwasher is feels like its shocking them when being wiped down													
Checked wiring all is good. Used volt meter to a know ground and no voltage seen. Tested by running and touching it our selfs. Not shocking us.													

..... good. over our meter to a kilow ground and no voltage seen. I tested by running and touching it our selfs. Not shocking us.

Completed	Non-PM	Low	Preventive Maintenance ^e	General Maintenance	Facilities	HR Building	Lindale Cummings	09/13/2023	09/15/2023	09/21/2023	0.00	0.00
New White Board - Please Hang												
Hung white board up												

Hung white board up

	Declined	Non-PM	Low	Preventive Maintenance	Other	Facilities	County Jail				
WO000260								09/11/2023	09/11/2023	0.00	0.00
Abandoned/Deliver Jail Pallets: We are requesting help with the pallets outside the jail's shipping & receiving garage doors as they need to be transported to the recycling center and placed on the southside of the Sheriff's Office Complex container for operational/evidential purposes. Teresa - The Evidence Supervisor is the point of contact for this request. Her extension is 5348.											

for operational and evidential purposes. I am a - the Evidence Supervisor is the point of contact for this request. Her extension is 5348. I am a - the Evidence Supervisor is the point of contact for this request. Her extension is 5348.

This can be handled by the sheriff's department with their trucks . Sorry for any inconvenience. Richard Teague.

WO#	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	09/08/2023	09/08/2023	09/11/2023	36.22	2.00
Toilet 231 is back flowing into 232													
Toilet 231 was full of trash and flooding.													

Toilet 231 was full of trash and flooding.

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cumings	09/08/2023	09/11/2023	09/11/2023	22.64	1.25
The Sink in B 138 and the small shower is not draining properly making it unusable. Cleared sink with an air plunger.													

Cleared sink with an air plunger.