

Work Order Summary w/ Details

Date Printed: 07/20/2026

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO001193	In Progress	Non-PM	Medium	Reactive Maintenance	Mechanical	Facilities		Circuit Court Building	Lindale Cummings	07/17/2026	07/20/2026		0.00	0.00
----------	-------------	--------	--------	----------------------	------------	------------	--	------------------------	------------------	------------	------------	--	------	------

Date called and said the judges door to the parking lot is not working again.

WO001192	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/17/2026	07/17/2026	07/17/2026	18.11	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	-------	------

D Pod Right Shower, issues with water coming out

Replaced bad flow valve

WO001191	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities		Historic Building	Lindale Cummings	07/17/2026	07/17/2026	07/17/2026	18.11	1.00
----------	-----------	--------	------	----------------------	----------	------------	--	-------------------	------------------	------------	------------	------------	-------	------

the faucet in the mens bathroom is not working.

Replaced faucet

WO001190	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/15/2026	07/15/2026	07/16/2026	18.11	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	-------	------

Sally Port Area #1, leak from the ceiling

Replaced over flow protector and gaskets in f pod

WO001189	Completed	Non-PM	Medium	Reactive Maintenance	HVAC	Facilities		HR Building	Richard Teeque	07/13/2026	07/13/2026	07/13/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	------	------------	--	-------------	----------------	------------	------------	------------	------	------

there isnt any air blowing from the vent

I lowered the thermostat temperature and unit started to working. I have no issue with the unit.

WO001188	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/13/2026	07/13/2026	07/15/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 2 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

A Pod Shower pump is not working, both showers

Fixed both showers.

WO001187	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/10/2026	07/10/2026	07/10/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

B Pod Cell 137 Sink spraying water

Replaced the flow through Valve

WO001186	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/10/2026	07/10/2026	07/10/2026	18.11	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	-------	------

E Pod (R) side shower has lost pressure

Replaced the Flow through valve

WO001185	New Work Order	Non-PM	Medium	Reactive Maintenance	Special Projects	Facilities		Justice Center	Richard Teague	07/08/2026	07/09/2026		0.00	0.00
----------	----------------	--------	--------	----------------------	------------------	------------	--	----------------	----------------	------------	------------	--	------	------

Is there anyway the sweet guys could come tomorrow before 11:30 and move all the leftover furniture/items that are in the lobby to the back hallway for me? We have a retirement party tomorrow from 12 - 1 in visiting courtroom and I know it would look nicer if they were not in the lobby. I may be given some of the items away to county but I have to make sure none of the judicial needs the left over items and I haven't had a chance to send out an email. thank you please!

WO001184	Completed	Non-PM	Low	Reactive Maintenance	Other	Facilities		Justice Center	Richard Teague	07/06/2026	07/07/2026	07/08/2026	0.00	0.00
----------	-----------	--------	-----	----------------------	-------	------------	--	----------------	----------------	------------	------------	------------	------	------

Could the guys move her office stuff back into her office tomorrow? She is out tomorrow but said they could put it back and then if she needed any help moving things around on Wednesday she will let us know, they should be done with the trim this afternoon in her office. And the main office area - the trim may be done by today as well. I know behind Michele and Britany are matching book shelves that go back there and their desk moved to the walls by Melody's desk - which is by my old desk, we have a shelf that can go back in - but I am waiting for her to tell me which one she wants. Thanks

Done.

WO001183	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	07/02/2026	07/02/2026	07/02/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Work Order Summary w/ Details

Date Printed: 07/20/2026

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

F Pod Sink Stopped Up

Pod officer said lady's in 248 said it was draining fine now

WO001182	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		County Jail	Lindale Cummings	07/02/2026	07/02/2026	07/02/2026	0.00	0.00
F Pod 246 Light Out														

Put in new bulbs.

WO001181	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities		Circuit Court Building	Kit Grimes	06/30/2026	06/30/2026	07/01/2026	0.00	0.00
----------	-----------	--------	------	----------------------	----------	------------	--	------------------------	------------	------------	------------	------------	------	------

Prosecutors office - Sensor on sink in restroom needs new batteries or fixed- cleaned it and still doesnt work
Installed new faucet

WO001178	Completed	Non-PM	High	Reactive Maintenance	Mechanical	Facilities		County Jail	Lindale Cummings	06/29/2026	06/29/2026	07/01/2026	0.00	0.00
----------	-----------	--------	------	----------------------	------------	------------	--	-------------	------------------	------------	------------	------------	------	------

Kitchen Door Slider not working from tower or by key

Took cover off and determined it was the new program issue they called out the other company said it just started working

WO001177	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		County Jail	Lindale Cummings	06/24/2026	06/25/2026	07/10/2026	18.11	1.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	-------	------

Lights replaced in old vending room

Lights are on order at Loyd's electric. Installed new ballistic

WO001175	Completed	Non-PM	Medium	Reactive Maintenance	Other	Facilities		County Jail	Lindale Cummings	06/24/2026	06/25/2026	06/25/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	-------	------------	--	-------------	------------------	------------	------------	------------	------	------

F Pod needs TV replaced, there is another 24" TV right in side 54's

Replace TV with new one

Work Order Summary w/ Details

Date Printed: 07/20/2026

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hours(s)
Work requested														
Action Taken														
Comments														

WO001176 Completed Non-PM Medium Reactive Maintenance Lighting Facilities County Jail Lindale Cummings 06/24/2026 06/25/2026 06/25/2026 18.11 1.00

Lights replaced in back stairwell going from lower

Replace bulbs

WO001174 Completed Non-PM Medium Reactive Maintenance Plumbing Facilities County Jail Kit Grimes 06/23/2026 06/24/2026 06/24/2026 0.00 0.00

E Pod Right side shower won't turn off

Changed out flow through valve. Works fine Took 45 minutes to get me in E pod.

WO001173 Completed Non-PM Medium Reactive Maintenance Mechanical Facilities County Jail Richard Teague 06/23/2026 06/23/2026 06/23/2026 0.00 0.00

54A is making a noise when opening and closing door

Checked. door was working as it should with no issues.

WO001172 New Work Non-PM Low Reactive Maintenance Lighting Facilities Justice Center Lindale Cummings 06/22/2026 06/24/2026 0.00 0.00

the light that is on all the time, right after you walk in to my main office upstairs - and it has a new light system - it flickers. I think there was issues before the switch - but Tayler was having a hard time figuring out what was the one flickering. and now I finally saw it as well. thanks

WO001171 Declined Non-PM Low Reactive Maintenance Plumbing Facilities County Jail 06/22/2026 06/22/2026 0.00 0.00

B-138 - toilet not draining properly

No action required. This is a duplicate ticket.

Work Order Summary w/ Details

Date Printed: 07/20/2026

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hours
Work requested														
Action Taken														
Comments														

WO001170 Completed Non-PM Medium Reactive Maintenance Plumbing Facilities County Jail Lindale Cummings 06/22/2026 06/22/2026 06/22/2026 0.00 0.00

B-138 - toilet not draining properly

Took pieces of the sheet out of the drain pipe

WO001169 Completed Non-PM Medium Reactive Maintenance Special Projects Facilities Historic Building Kit Grimes 06/16/2026 06/16/2026 06/17/2026 0.00 0.00

Office Furniture needs put together

Put hutch together

WO001168 Completed Non-PM Medium Reactive Maintenance Carpentry Facilities Justice Center Kit Grimes 06/16/2026 06/17/2026 06/18/2026 18.11 1.00

Danielle wondered if we could have a piece of wood, painted black that the guys could mount above the TV mount for the box that is currently sitting on my bookcases? It would look nicer, however I am not for sure how hard it would be to get to it, if needed.

Bought brackets and bored to put up when ready

WO001167 Declined Non-PM Low Reactive Maintenance Painting Facilities Justice Center 06/16/2026 06/16/2026 0.00 0.00

I think we should just go ahead and plan on having Danielle and i's offices repainted before we put the furniture back. I didn't know if this is something Kit & Lindale would do or Hambey & then I assume I would ask them. I was thinking that Thursday July 1 would work? then give the whole weekend for it to dry. I also know we may need to dust the walls before any paint is on since it will be dusty from the carpet removal.

We don't have the time.

WO001166 Completed Non-PM Medium Reactive Maintenance Plumbing Facilities Historic Building Lindale Cummings 06/15/2026 06/15/2026 06/15/2026 0.00 0.00

Someone just stopped in my office and said that the chain is broken in one of the toilets in the women's restroom and it's not flushing.

Attached the chain back to the flush valve

WO001165 Completed Non-PM Medium Reactive Maintenance Elevators Facilities Justice Center Richard Teeque 06/15/2026 06/15/2026 06/15/2026 0.00 0.00

Work Order Summary w/ Details

Date Printed: 07/20/2026

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hours
Work requested														
Action Taken														
Comments														

Back elevator isn't working.

Reset elevator

WO001163	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	06/15/2026	06/15/2026	06/15/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

EPOD toilet is not working or flushing

Call that commissary trash

WO001164	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	06/15/2026	06/15/2026	06/15/2026	0.00	0.00
----------	-----------	--------	------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

DPOD shower (L) constantly running

New flow valve

WO001162	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		County Jail	Lindale Cummings	06/15/2026	06/15/2026	06/15/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

APOD (L) shower light is out

New bulbs

WO001161	Completed	Non-PM	Medium	Reactive Maintenance	General Maintenance	Facilities		Circuit Court Building	Lindale Cummings	06/15/2026	06/15/2026	06/15/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	---------------------	------------	--	------------------------	------------------	------------	------------	------------	------	------

The right main entrance door is not latching properly.

Door closes as it should now

WO001160	Completed	Non-PM	Medium	Preventive Maintenance	HVAC	Facilities		County Jail	Lindale Cummings	06/15/2026	06/15/2026	06/15/2026	0.00	0.00
----------	-----------	--------	--------	------------------------	------	------------	--	-------------	------------------	------------	------------	------------	------	------

Clean all condenser unit coils over the jail.

Washed coil

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 7 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

				Preventive Maintenance	HVAC	Facilities	Justice Center	Richard Teague					
WO001159	Completed	Non-PM	Medium						06/15/2026	06/15/2026	06/15/2026	0.00	0.00
Clean the condenser to coil on the h-vac unit over the justice center.													
Washed out coils													

	Completed	Non-PM	Medium	Preventive Maintenance	HVAC	Facilities	Historic Building	Lindale Cummings	06/11/2026	06/11/2026	06/12/2026	0.00	0.00
WC0001158													
The plane condenser coils on all units at a historic courthouse.													
All coils have been cleaned out for this building													

WO#	Completed	Non-PM	Medium	Preventive Maintenance	HVAC	Facilities	Circuit Court Building	Lindale Cummings	06/11/2026	06/11/2026	06/12/2026	0.00	0.00
WO001157	Completed	Non-PM	Medium	Preventive Maintenance	HVAC	Facilities	Circuit Court Building	Lindale Cummings	06/11/2026	06/11/2026	06/12/2026	0.00	0.00
Clean condenser coils on a hundred and forty ton H-vac unit.													
Cleaned condenser coils													

WO#	Completed	Non-PM	High	Reactive Maintenance	HVAC	Facilities	HR Building	Richard Teague	06/1/2026	06/11/2026	0.00	0.00
WO001156	Completed	Non-PM	High						06/1/2026	06/11/2026	0.00	0.00

WO#	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities	County Jail	Kit	Grimes	06/08/2026	06/08/2026	06/09/2026	0.00	0.00
WO001155	Completed	Non-PM	High							06/08/2026	06/08/2026	06/09/2026	0.00	0.00
Pod shower on LEFT is stuck open														
Timed water for 1 minute														

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 8 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hours
Work requested														
Action Taken														
Comments														

WO001154	Completed	Non-PM	Low	Reactive Maintenance	Lighting	Facilities		Justice Center	Lindale Cummings	06/04/2026	06/08/2026	06/09/2026	0.00	0.00
----------	-----------	--------	-----	----------------------	----------	------------	--	----------------	------------------	------------	------------	------------	------	------

Above Sue's desk we had the guys take out a light, but we think it is too dark there, could you please put the light back on? This is in the back corner - area behind visiting courtroom, thanks

Put light back in

WO001153	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		Justice Center	Lindale Cummings	06/02/2026	06/03/2026	06/04/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	----------------	------------------	------------	------------	------------	------	------

Good Afternoon, I was informed by the Bailiff for Judge Bacon that there lights out in the courtroom. Thank you.

Replaced bulbs

WO001152	Completed	Non-PM	Medium	Reactive Maintenance	HVAC	Facilities		HR Building	Richard Teague	06/01/2026	06/02/2026	06/02/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	------	------------	--	-------------	----------------	------------	------------	------------	------	------

We don't think the front lobby air conditioning is working. The air coming from the vents is not as cool as the rest of the office. The thermostat is set at 71; however the temperature is 75.

Found an electrical issue at the disconnect. Repaired issue unit is working as I should.

WO001151	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	06/01/2026	06/01/2026	06/01/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Cell 232 - Sink is not draining properly and is backing up when toilet is flushed

Took air plunger and freed up clog

WO001150	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities		Historic Building	Richard Teague	06/01/2026	06/01/2026	06/11/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------------	----------------	------------	------------	------------	------	------

Replace outdoor lighting control on historic courthouse.

Replaced control and programmed.

WO001149	Completed	Non-PM	Medium	Reactive Maintenance	Carpentry	Facilities		Justice Center	Lindale Cummings	05/29/2026	06/01/2026	06/01/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	-----------	------------	--	----------------	------------------	------------	------------	------------	------	------

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 9 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

Can you please have the guys add some brackets to my desk to keep it up until I get it replaced?thanks

Put brackets on desk. Should be fine

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	05/28/2026	05/28/2026	05/29/2026	0.00	0.00
WO001148	Completed	Non-PM	Medium									0.00	0.00
here is a light out in our hallway by the coffee area													
light was fully functional upon arrival													

There is a light out in our hallway by the coffee area
.....
Light was fully functional upon arrival

—light was fully functional upon arrival

WO#	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	05/27/2026	05/28/2026	05/29/2026	0.00	0.00
WO001147	Completed	Non-PM	Medium	Reactive Maintenance	Lighting	Facilities	Justice Center	Lindale Cummings	05/27/2026	05/28/2026	05/29/2026	0.00	0.00
THERE IS A LIGHT IN THE DOWNSTAIRS WOMENS OFFICE BATHROOM THAT IS HANGING OUT OF THE CEILING AND THERE IS A LIGHT IN THE UPSTAIRS OFFICE THAT IS FLICKERS EVERY NOW AND THEN, we did let indale and kit know but we knew it has to be in here too													
Fixed both issues													

THERE IS A LIGHT IN THE DOWNSTAIRS WOMENS OFFICE BATHROOM THAT IS HANGING OUT OF THE CEILING AND THERE IS A LIGHT IN THE UPSTAIRS OFFICE THAT IS FLICKERS EVERY NOW AND THEN, we did let Indale and kit know but we knew it has to be in here too

fixed both issues

				Reactive Maintenance	Lighting	Facilities	County Jail	Lindale Cummings			
WO001146	Completed	Non-PM	Medium					05/26/2026	05/26/2026	05/26/2026	0.00
Pod showers are not draining											
Poured clobber down the drain and adjust time on showers											

Pod showers are not draining

...oured clobber down the drain and adjust time on showers

V0001145	Completed	Non-PM	Medium	Reactive Maintenance Lighting e	Facilities	County Jail	Lindale Cummings	05/26/2026	05/26/2026	05/26/2026	0.00	0.00
Pods shower light needs replaced												
replaced bulbs												

Pods shower light needs replaced

Replaced bulbs

Case Number	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities	County Jail	Lindale Cummings	05/26/2026	05/26/2026	05/26/2026	0.00	0.00
0001144	Completed	Non-PM	Medium				County Jail	Lindale Cummings	05/26/2026	05/26/2026	05/26/2026	0.00	0.00
Toilet has been plunged and still stopped up													
mate had tore up sheet and flushed down toilet													

toilet has been plunged and still stopped up

mate had tore up sheet and flushed down toilet

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 10 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO001142	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	05/25/2026	05/26/2026	05/26/2026	0.00	0.00
Toilet is clogged. Toilet won't flush properly despite using the plunger.														
Was 2 wash cloths flushed by same inmate in Epod														

WO001143	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		County Jail	Lindale Cummings	05/25/2026	05/26/2026	05/26/2026	0.00	0.00
Toilet is clogged. Toilet won't flush properly despite using the plunger.														
Duplicate order. Was fixed														

WO001141	Completed	Non-PM	Medium	Vandalism	Plumbing	Facilities		County Jail	Kit Grimes	05/24/2026	05/26/2026	05/26/2026	10.25	0.50
Toilet is clogged. Did not unclog despite using plunger multiple times.														
Removed lots of commissary trash same inmate as a pod and epod														

WO001140	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities		Historic Building	Lindale Cummings	05/21/2026	05/22/2026	05/22/2026	0.00	0.00
Water runs continuous in the Urinal of the mens bathroom.														
Went and checked all bathrooms. Don't find any issues with any of them														

WO001139	Completed	Non-PM	High	Vandalism	Plumbing	Facilities		County Jail	Kit Grimes	05/20/2026	05/20/2026	05/21/2026	0.00	0.00
D Pod Shower button has fallen off and shower is running non stop														
New button assembly														

WO001138	Completed	Non-PM	High	Reactive Maintenance	Plumbing	Facilities		County Jail	Kit Grimes	05/20/2026	05/20/2026	05/21/2026	0.00	0.00
----------	-----------	--------	------	----------------------	----------	------------	--	-------------	------------	------------	------------	------------	------	------

Page 11 of 218

C Pod Shower running non stop

.....

Replace flush valve

.....

ut on new flusher

Page 12 of 218

.....

.....

Work Order Summary w/ Details

Date Printed: 07/20/2026

Page 13 of 218

Work Order #	WO Status	Origin	Priority	Work Type	Work Category	Site	Source Asset	Source Location	Assigned To	Originated	Expected	Completed	Cost \$	Hour(s)
Work requested														
Action Taken														
Comments														

WO001127	Completed	Non-PM	Medium	Reactive Maintenance	Plumbing	Facilities		Historic Building	Lindale Cummings	04/28/2026	04/29/2026	04/29/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	----------	------------	--	-------------------	------------------	------------	------------	------------	------	------

Toilet will not flush

Checked both toilets on 2nd floor and both flush as they should

WO001126	Completed	Non-PM	Medium	Reactive Maintenance	General Maintenance	Facilities		Circuit Court Building	Lindale Cummings	04/28/2026	04/28/2026	04/29/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	---------------------	------------	--	------------------------	------------------	------------	------------	------------	------	------

The water fountain on the 2nd floor at CCB is not working.

gfi tripped and filter needed changed

WO001125	Completed	Non-PM	Low	Reactive Maintenance	Other	Facilities		Justice Center	Lindale Cummings	04/27/2026	04/28/2026	04/28/2026	0.00	0.00
----------	-----------	--------	-----	----------------------	-------	------------	--	----------------	------------------	------------	------------	------------	------	------

Sheriff has expressed his disliking of the placement of the corkboard that you all have so kindly attached to the wall already. He has asked that it be moved to a more centered position to match the center of the corkboard that is hanging across the hall.

Completed the move to the sheriffs standards

WO001124	Completed	Non-PM	Medium	Reactive Maintenance	Elevators	Facilities		Justice Center	Lindale Cummings	04/27/2026	04/27/2026	04/28/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	-----------	------------	--	----------------	------------------	------------	------------	------------	------	------

The elevator tech is at JC waiting on someone from maintenance to meet with him. He'll be at the front desk.

Done.

WO001123	Completed	Non-PM	High	Reactive Maintenance	Lighting	Facilities		HR Building	Lindale Cummings	04/24/2026	04/27/2026	04/28/2026	0.00	0.00
----------	-----------	--------	------	----------------------	----------	------------	--	-------------	------------------	------------	------------	------------	------	------

Light inside elevator is flashing like a strobe light. Was asked to have you look at it so that it doesn't cause someone to have a seizure.

Put in new lightbulbs with a ballast

WO001122	Completed	Non-PM	Medium	Reactive Maintenance	General Maintenance	Facilities		Circuit Court Building	Lindale Cummings	04/24/2026	04/27/2026	04/28/2026	0.00	0.00
----------	-----------	--------	--------	----------------------	---------------------	------------	--	------------------------	------------------	------------	------------	------------	------	------

A

D

Page 14 of 218

Dis

Aarooil

dr

•

PO

Alle

Page 15 of 218

.....

.....